

24/08/2021

<u>Public Tender No. 21009639 - Goods: 2 Portable Flexible</u> <u>Tanks</u>

Please see below EAPC clarifications and replies to questions and comments received from potential participants:

EAPC replies and clarifications below become an integral part of this Tender and will force the bidders.

Please pay attention the deadline for submitting proposals will be postponed to 2nd of September 2021 at 11:00 Israeli Time.

EAPC Replies

	Question	Reply
1.	Here are a couple of questions before quoting the required fuel collapsible bladders to you.	
	Can we have the Material Safety data Sheet of the fluid stored in the requested bladders? Preferred fitting is an OPW connection has to be fitted at the end of each port. OPW being a brand	Please see attached MSDS The fitting is to be stainless steel CAMLOCK coupling
2.	We have some questions / comments regarding your specification:	
	The spec calls for resistance to fuel distillates and crude oil, but also requests conformance with Mil-T-52983 and U.S. DOD ATPD 2266. Although tank materials that comply with Mil-T-52983 and U.S. DOD ATPD 2266 offer short term resistance to fuel distillates and crude oil, this material is not appropriate for longer term storage of these materials. If longer term storage is required, there are other bladder materials that are more appropriate.	
	Which is more important, conformance to your listed spec(s), or compatibility with distillates and crude oil?	You can go with the MIL-PRF-32233 the latest military spec



3.	Could you clarify if the tanks must be open top?	The tanks are closed
٦.	Could you clarify if the talks must be open top:	The tanks are closed
4		
4.	Our company represents in Israel " leading manufacture of	
	inflatable fuel and water tank systems to the US Army, Navy and	
	Airforce .	
	https://www.gtacontainers.com	
	Following are their comments to the specifications:	
	We can supply these with the following provisions:	
	They will be made to MIL-PRF-32233, this is the latest military	
	spec that superseded the two specs given	This speck is OK
5.	If the tanks to have elbows hoses and valves we would prefer to	OK
	send 4" with adaptors to 3" as it would be stock hardware for us.	
6.	Our supplier asks:	According to clause 6.7.
0.	What are the payment terms? We do not find payment terms in	"Bidder shall specify <u>his</u> payment
	the tender documents.	terms in relation to the goods
	the tender documents.	offered. It is hereby clarified that any
		1
		proposal which will include a request
		to get any payment before shipment
		might be disqualified"