

24/10/2021

Procedure No. 21011894 Goods:
Butterfly Valves

Please see below EAPC clarifications and replies to questions and comments received from potential participants:

EAPC replies and clarifications below become an integral part of this Tender and will force the bidders.

EAPC Replies

	Question	Reply
1.	What is the quantity required ?	See Updated specifications in the website from date 13.10.2021.
2.	<p>We are aware of the questions/clarifications closing date of 19-october 2021, however we received today question from Valve manufacturer.</p> <p>In the description the valve is required lug type, however the face-to face specified in the same file is applicable to a double flanged valve long pattern according to API 609 cat B (also in the EAPC purchase requirement it is requested double flanged).</p> <p>Can you please confirm that I have then to quote a lug type valve but with a special face-to-face, or just double flanged valve?</p>	In the description the valve is required lug type - meaning that the 2 sides of the valve will have threading and they could be assembly to a normal flange.